



SUMMARY INFORMATION SHEET

September 2011
FSEC # 00534N

MANUFACTURER

Company Ezinc Metal Sanayi ve Ticaret A.S.
Address Organize Sanayi Bolgesi 23.Cad No: 31 Kayseri, TR-38070 Turkey

Collector Model
Superline L USB

This solar collector was evaluated by the Florida Solar Energy Center (FSEC) in accordance with prescribed methods and was found to meet the minimum standards established by FSEC. This evaluation was based on solar collector tests performed by an FSEC approved laboratory. The purpose of the tests is to verify initial performance conditions and quality of construction only. The resulting certification is not a guarantee of long term performance or durability.

DESCRIPTION

Gross Length	1.891 meters	6.2 feet
Gross Width	1.205 meters	3.95 feet
Gross Depth	.099 meters	.325 feet
Gross Area	2.279 square meters	24.53 square feet
Transparent Frontal Area	2.222 square meters	23.92 square feet
Volumetric Capacity	2.8 liters	.7 gallons
Weight (empty)	40 kilograms	88 pounds
Test Pressure	1350 kPa	195.8 Psig
Number of Cover Plate	1	

MATERIALS

Enclosure	Aluminum
Glazing	Tempered Glass
Absorber	Copper with Copper
Absorber Coating	Selective
Insulation	Polyurethane, Fiber glass

THERMAL PERFORMANCE

Test flow Rate 59 ml/s .94 gpm

Incident Angle Modifier [(S)=1/cosθ - 1, 0°<θ<=60°] Kτa = 1 -0.383 (S) 0.040 (S)²

Efficiency Equation [NOTE: Based on gross area and (P)=Ti-Ta]

				Y INTERCEPT	SLOPE
S I UNITS:	η= 0.737	-3.59960 (P)/I	-0.01006 (P) ² /I	0.732	-4.20 W/m ² .°C
I P UNITS:	η= 0.737	-0.63410 (P)/I	-0.00100 (P) ² /I	0.732	-0.70 Btu/hr.ft ² .°F

RATING

This collector has been rated for energy output on measured performance and an assumed standard day. Total solar energy available for the standard day is 5045 Watt-hour/m² (1600 Btu/ft²) distributed over a 10 hour period.

Output energy ratings for this collector based on the second-order efficiency curve are:

Collector Temperature		ENERGY OUTPUT			
Low	35 °C (95 °F)	7.86	kWh/day	26800	Btu/day
Intermediate	50 °C (122 °F)	6.579	kWh/day	22400	Btu/day
High	100 °C (212 °F)	2.8	kWh/day	9600	Btu/day

